



NATIONAL ALUMINIUM COMPANY LIMITED  
CAPTIVE POWER PLANT, ANGUL – 759 145

**PARTICULATE EMISSION AT ESP OUTLET THROUGH  
STACK  
FOR THE MONTH OF JULY – 2021**

UNIT NO	NO OF TESTS PERFORMED	NORMS IN mg/Nm <sup>3</sup>	SPM in mg/Nm <sup>3</sup>		AVERAGE SPM in mg/Nm <sup>3</sup>
			MIN/DATE	MAX/DATE	
1	0	100	s/d	s/d	s/d
2	0	100	s/d	s/d	s/d
3	02	100	83.33 (05.07.2021)	87.51 (17.07.2021)	86.34
4	02	100	86.56 (19.07.21)	89.66 (06.07.21)	88.44
5	02	100	82.87 (07.07.2021)	87.65 (20.07.2021)	85.26
6	02	100	85.40 (08.07.2021)	89.70 (21.07.2021)	87.55
7	02	100	80.28 (09.07.2021)	89.40 (22.07.2021)	84.84
8	02	50	36.84 (23.07.2021)	37.55 (10.07.2021)	37.19
9	0	50	s/d	s/d	s/d
10	02	50	32.16 (26.07.2021)	35.11 (14.07.2021)	33.63